



- NOTES :**
- 1) THE EXISTING VRF CONDENSING UNITS TO BE RETAINED
 - 2) THE EXISTING DUCTABLE UNITS TO BE REPLACED BY SINGLE AHU
 - 3) THE EXISTING FRESH AIR INTAKE SHALL BE RETAINED
 - 4) THE CONDENSATE DRAIN OF THE NEW UNITS SHALL BE CONNECTED TO THE EXISTING DRAIN POINT
 - 5) EXISTING DUCTING WORK & GRILLES RETAINED
 - 6) INTERNAL CLEANING OF DUCTING TO BE CARRIED OUT

| | | | | | | | | | | |
|---------------------------------|----------------------------------|--|--|---|--|--|--|---|--|--|
| sketch no 2406-SK-21B | | project CSMVS MAIN BUILDING RENOVATION & UPGRADATION | | title COOMARASWAMY HALL LAYOUT - HVAC (DXUNITS) | | north  | |  | | |
| scale 1:100 | clients CSMVS, mumbai. | | | | | | | | | |
| date 2018/06/28 | | | | | | | | | | |